



2462 Patterson Bridge Ext.
Hephzibah, GA 30815

Phone: (706) 592-4029

Website: <https://mtimfg.com>

UNLESS OTHERWISE
SPECIFIED ALL DRAWINGS
ARE IN INCHES

TOLERANCES ARE: +/- 1/8"

Description:
Adapter Curb Installation Guide

Part Number:

Quantity:

ADAPTER CURB INSTALLATION

1. Before removing existing unit, verify the dimensions of the existing curbs O.D. & the new unit with the enclosed drawings. (Note the adapter curb is oversized by 1" in both directions.)
2. Remove the old unit and confirm the return & supply sizes and locations with the enclosed drawings.
3. Remove all old gasket materials from the existing curb and then replace with new gasket materials, which are supplied with the curb.
4. Set adapter curb on the existing curb in the necessary orientation.
5. Apply gasket material to the top rails and perimeter of the new adapter curb.
6. New unit is to be set on adapter curb.
7. **A licensed professional is to reconnect necessary utilities to the new rooftop unit and verify that utilities are connected before turning back on.**

